



- SHEET NOTES:**
- 1 12X12 200
 - 2 8" 100
 - 3 12" 200
 - 4 12" 200
 - 5 24X24 115
 - 6 12X12 180
 - 7 24X24 300
 - 8 24X24 50
 - 9 PROVIDE FIRE SMOKE DAMPER IN 14X14 DUCT AT MECHANICAL ROOM WALL.

30X60 LOUVER BY ARCHITECT. CONNECT 30X32 AND 30X12 DUCTS TO LOUVER WITH 30X12 BLANK OFF PIECE BETWEEN DUCTS. PROVIDE BACKDRAFT DAMPERS BEHIND LOUVERS.

PARTIAL HVAC PLAN
SCALE: 1/8"=1'-0"
NORTH

Issue	Description	Date
1	CONSTRUCTABILITY REV.	3-25-02
2	CONSTRUCTABILITY REV.	4-5-02
3	BID SET	4-22-02
4	CONSTRUCTION SET	6-28-02

Project Title: _____

SNOHOMISH LIBRARY

Revision	Description	Date

Sheet Title:
PARTIAL HVAC PLAN

Scale: 1/8"=1'-0"
Project No: 20022
Date: 06-28-02

Sheet No: _____

M1.1
CONST. SET 6-28-02